

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1521:124 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Siemens Building Technologies, Inc., 1000 Deerfield Parkway, Buffalo Grove, IL 60089
Contact: Ferd Orpano (847) 941-6176 FAX (866) 699-0238

DESIGN: Models G1 single gang strobe light, followed by -R, *-F or none, followed by -V, followed by -15, -30, -60, or -75, or *-110, *followed by -LG. *The suffix F refers to a silk-screened word "FIRE" on the strobe housing (not on the lens). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 24-30 VDC
Candela: 15cd, 30cd, 60cd, 75cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. For indoor use and wall mount only. Refer to listee's Installation Instruction Manual for details.

XLF: 7125-1591:203

*Rev. 03-16-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MARCH 16, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**